

Fire Application #329004 - MADISON HOUSE ROOM REMODEL TI

[illegible]



Fire Application #329004 - MADISON HOUSE ROOM REMODEL TI

Project Contact

Company Name: Smith Fire Systems, Inc.

Name: Tangi AlfredNorris **Email:** talfrednorris@smithfire.com

Address: 1106 54th Avenue E **Phone #:** (253) 926-1880 2009
Tacoma WA 98424

Project Type	Activity Type	Scope of Work
Mixed Use	Alteration	Fire Sprinkler Systems

Project Name: MADISON HOUSE ROOM REMODEL TI

Description of Work: MODIFY THE EXISTING SPRINKLER SYSTEM TO ACCOMMODATE THE DEMO;D
WALLS

Project Details

System Information

This is a modification or addition to an existing system

Fire System Type

NFPA 13

Alterations

There are no alterations to devices or systems.

Quick Response or Recalled Head Change Out

The K-Factor and spacing match existing.

Quick Response or Recalled Head Relocation

Heads are being relocated.

Change of Use

This is not a change of use.

Hydraulic Calculations

There is no change to the hydraulic calculations.

Hazard Classification

The space is classified as Light/Ordinary Hazard.

Mains and Cross Mains

Mains or cross mains are not being relocated.

Heads - Excluding Quick Response and Recalled

1 - 25 total heads

Fire System Counts

Number of Heads Relocated	13
Number of Total Heads	13